

BASE OF UNIT EXTENDS
1/2" MINIMUM [13mm]
BEYOND AND DOWN OVER
TOP OF CURB

SEALING MATERIAL—MUST
BE CONTINUOUS ON THE
PERIMETER

WOOD NAILER NOMINAL
2" X 4" [51mm X 102mm]

FLASHING RECEIVER

8" MIN.
[203mm]

1" MIN. [25mm]

FASTENERS 8"
O.C. [203mm]

COUNTERFLASHING

60MIL THERMOPLASTIC
FB MEMBRANE
3" MIN ON FIELD,
HEAT WELD

BASE FLASHING
PLY 6" MIN.
[152mm] ON FIELD

60MIL THERMOPLASTIC
FB MEMBRANE

MECH DECK

UNIT MOUNTING CURB

CANT—FASTENED TO NAILER

BASE PLY

INSULATION, STAGGER
ALL JOINTS, FASTEN
PER SPECIFICATIONS

ALL PLIES SET IN ADHESIVE SEE
SPECIFICATIONS FOR ADHESIVES



THE GARLAND COMPANY, INC.
GARLAND CANADA, INC.
THE GARLAND COMPANY UK, LTD

DETAIL:

CURB DETAIL/AIR HANDLING STATION

KEE HYBRID